

3516B Daily Visual Check of Pressure Differential Indicators (PDI's)

Generator# _____ **Week#** _____ **Month** _____ **Year** _____

Visually inspect the PDI's for a tripped condition: yellow diaphragm enters red zone, red piston locks in the visible position, or air restriction reaches predetermined psdi.

Maximun allowable psid for the air filter elements are: 6kPa (25 inches of water)

Maximun allowable psid for the oil filter elements are: 103kPa (15 psi)

Maximun allowable psid for the fuel filter elements are: 103kPa (15 psi)

If any air filter PDI's are tripped, reset and monitor that indicator. If this PDI trips again alert the US Power lead technician.

If any PDI's are tripped on the oil filter or fuel filter, alert the US Power lead technician.

	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday
Air filter (L)							
Air filter (L/C)							
Air filter (R/C)							
Air filter (R)							
Oil filter							
Fuel filter							

Signature _____